

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0694:208 Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** Fire Control Instruments, 301 2<sup>nd</sup> Avenue, Waltham, MA 02451-1133  
Contact: Anthony J. Shalna (781) 471-3000\*

**DESIGN:** Models H12/24-FC, H12/24W-FC, HC12/24-FC, HC12/24K-FC and HC12/24W-FC sounders. All units are not suitable for public mode fire alarm service when used at low volume on 12V control panels. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 10.5 - 30 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as audible devices for use with separately listed compatible fire alarm control units. For indoor use only.

Units can generate the Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) as required per NFPA 72, 1996 Edition.

**XLF:** 7135-1209:143

\*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager